

4-2-3: INTERNATIONAL FIRE CODE ADOPTED; EXCEPTIONS; ADDITIONS:

(A) Code Adopted: The International Code Council Fire Code, 2015 edition is hereby adopted by reference as the Fire Code of the Village subject to such deletions and additions of sections as hereinafter provided.

(B) International Fire Code with additions, deletions and insertions:

1. Section 101.1 insert Village of Barrington Hills

2. Enforcement Authority:

Insert section 103.5 Code Official: It shall be the duty and responsibility of the building officer of this village as is designated by the president and board of trustees of this village to enforce the building code of this village among which is included the fire prevention code and its provisions herein set forth. The designated enforcement officer of this code is herein referred to as the code official and shall mean the building officer of this village.

3. Duties and Powers of the Code Official:

Insert 104.12: The president and board of trustees may adopt rules and regulations to implement the provisions of this chapter.

4. Open Burning:

Delete section 307.1 and 307.2 and insert the following:

307.1 General:

General: An outdoor fire shall occur in accordance with the provisions of this code by burning certain material and releasing the products of combustion in the air without the use of a chimney.

307.1.1 Definitions: The following words and terms shall, for the purposes of this section and as stated elsewhere in this code, have the meanings shown herein.

Bonfire: An outdoor fire used for ceremonial purposes or for the disposal of landscape waste upon the premises where it is produced.

Landscape Waste: All accumulations of grass or shrubbery cuttings, leaves, cuttings and other materials accumulated as a result of lawns, shrubbery, vines and trees.

Open Burning: The burning of the material permitted by this code in an outdoor fire wherein products of combustion are emitted directly into the ambient air without passing through a stack or chimney from an enclosed chamber. For the purpose of this definition, a chamber shall be regarded as enclosed when, during the time combustion occurs, only apertures, ducts, stacks, flues or chimneys necessary to provide combustion air and permit the escape of exhaust gas are open.

Recreational Fire: An outdoor fire utilized to cook food for human consumption.

307.2 Allowable Burning:

Allowable Burning: Open burning shall be allowed without prior notification to the code official for bonfires, recreational fires or highway safety flares, smudge pots or similar occupational needs.

307.2.2 Permit Required:

Notification Required: Open burning for recognized silvicultural, prairie, range or wildlife management practices, and prevention or control of disease or pests shall require the prior notification to the code official

from the owner of the land to be kindled.

307.2.3 Application:

Notification: Notification of an open burning shall occur at least two (2) days before the fire is set, shall be provided in written or verbal form, and shall provide such information as required by the code official. Such notification shall provide, at a minimum, information regarding: the purpose of the proposed burning, the nature and quantities of material to be burned, the date and time when such burning shall take place, the location of the burning site, and the person who shall supervise the burning.

307.2.4 Open Burning Prohibited:

Open Burning Prohibited: Open burning shall not be utilized for waste disposal purposes, shall be of the minimum size for the intended purpose and the fuel shall be chosen to minimize the generation and emission of air contaminants. The code official shall prohibit open burning which will be offensive or objectionable due to smoke or odor emissions when atmospheric conditions or local circumstances make such fires hazardous. The code official shall order the extinguishment, by the property owner or the fire department, of any open burning which creates or adds to a hazardous or objectionable situation.

307.2.5 Location: The location for any open burning shall not be less than 100 feet (30480 mm) from any structure and provisions shall be made to prevent the fire from spreading to within 100 feet (30480 mm) of any structure. Fires in approved containers shall be permitted, provided that such fires are not less than 15 feet (4572 mm) from any structure. No more than one bonfire shall occur at any one time on the premises. Bonfires on any property shall be maintained in the same location on the premises throughout the year.

307.2.6 Attendance: Any open burning shall be constantly attended by the resident of the premises with a shovel or a rake until the fire is extinguished. At least one portable fire extinguisher with a minimum 4-A rating, two portable fire extinguishers with a minimum 2-A rating each, or other approved on-site fire extinguishing equipment, such as a garden hose attached to a water barrel, water truck or other method of water supply shall be available for immediate utilization.

307.2.7 Bonfire Size and Duration: A bonfire shall not be more than 5 feet (1524 mm) by 5 feet (1524 mm) by 5 feet (1524 mm) in dimension and shall not burn longer than 3 hours in any 24 hour period from the start of the bonfire. No bonfire shall be started or maintained other than between the hours of 10:00 A.M. to 10:00 P.M. The maximum size and duration of a bonfire shall not be increased by the code official unless it is determined that fire safety requirements of the situation and the desirable duration of burn warrant the increase.

307.2.8 Material: Fuel for a bonfire shall consist only of seasoned dry firewood, landscape waste, or untreated or unpainted lumber or scrap wood which is produced or obtained for use on the premises where the materials are burned. The fuel shall be ignited with a small quantity of paper. The fire shall not be used for any other waste or refuse disposal purposes and the fuel shall be chosen to minimize the generation and emission of air contaminants.

In lieu of section 903.41.6 Supervisory service:

All required commercial fire sprinkler systems shall transmit alarm and trouble signals to the communications console in the Barrington Hills police department.

5. Fire Alarm System Monitoring (Section 907.6.6)

In lieu of section 907.6.6 Monitoring:

All required fire alarm systems shall transmit alarm and trouble signals to the communications console in the Barrington Hills police department.

6. Sections 5704.2.9.6.1, 5706.2.4.4, 5806.2 and 6104.2 are not allowed without special permission as a Zoning Code Appeal

7. Chapter 80 Delete all references to the International Plumbing Code and insert the Illinois Plumbing Code (Ord. 18-09, 8-27-2018, eff. 1-1-2019)